



CFS Oaklyn
33 W. Haddon Avenue
Oaklyn, NJ 08107

2/14/2025 12:03
SAMPLE NUMBER: Y731
DATE SAMPLED: 1/30/25
DATE/TIME RECEIVED: 1/30/25 16:30
COLLECTED BY: Client

CERTIFICATE OF ANALYSIS

N.J.D.E.P. CERTIFICATION # 06003

Results in mg/l(ppm) unless otherwise noted

Sample #	Sample Location	Date Sampled	Time Sampled	DF	Lead	RL	Date/Time Analyzed
Y731-1	Pantry Sink F.D.	1/30/2025	6:00	1	<0.002	0.002	2/3/2025 12:36
Y731-2	Kitchen Sink F.D.	1/30/2025	6:01	1	<0.002	0.002	2/3/2025 12:41
Y731-3	Kitchen 3 Bay F.D.	1/30/2025	6:02	1	<0.002	0.002	2/3/2025 12:46
Y731-4	1st Fl. Children Bath 1 F.D.	1/30/2025	6:04	1	<0.002	0.002	2/3/2025 12:51
Y731-5	1st Fl. Children Bath 2 F.D.	1/30/2025	6:05	1	<0.002	0.002	2/3/2025 12:56
Y731-6	1st Fl. Water cooler	1/30/2025	6:07	1	<0.002	0.002	2/3/2025 13:01
Y731-7	1st Fl. Womans Bath F.D.	1/30/2025	6:08	1	<0.002	0.002	2/3/2025 13:06
Y731-8	1st Floor Mens Bath F.D.	1/30/2025	6:09	1	<0.002	0.002	2/3/2025 13:22
Y731-9	2nd Fl. Child Bath 1 F.D.	1/30/2025	6:12	1	<0.002	0.002	2/3/2025 13:37
Y731-10	2nd Fl. Child Bath 2 F.D.	1/30/2025	6:13	1	<0.002	0.002	2/3/2025 13:42
Y731-11	Staff Bath 2nd Fl. F.D.	1/30/2025	6:15	1	<0.002	0.002	2/4/2025 10:30
Y731-12	Water cooler 2nd Floor	1/30/2025	6:16	1	<0.002	0.002	2/4/2025 10:35
Y731-13	Classroom 1	1/30/2025	6:18	1	<0.002	0.002	2/4/2025 10:40
Y731-14	Classroom 2	1/30/2025	6:20	1	<0.002	0.002	2/4/2025 11:05
Y731-15	Classroom 3	1/30/2025	6:22	1	<0.002	0.002	2/4/2025 11:10
Y731-16	Classroom 4	1/30/2025	6:23	1	<0.002	0.002	2/4/2025 11:15
Y731-17	Classroom 5	1/30/2025	6:26	1	<0.002	0.002	2/4/2025 11:20
Y731-18	Classroom 6	1/30/2025	6:28	1	<0.002	0.002	2/4/2025 11:25

Latish Menghani
Lab Director



CFS Oaklyn
33 W. Haddon Avenue
Oaklyn, NJ 08107

2/14/2025 12:03
SAMPLE NUMBER: Y731
DATE SAMPLED: 1/30/25
DATE/TIME RECEIVED: 1/30/25 16:30
COLLECTED BY: Client

CERTIFICATE OF ANALYSIS

N.J.D.E.P. CERTIFICATION # 06003

Results in mg/l(ppm) unless otherwise noted

Sample #	Sample Location	Date Sampled	Time Sampled	DF	Copper	RL	Date/Time Analyzed
Y731-1	Pantry Sink F.D.	1/30/2025	6:00	1	0.428	0.05	2/4/2025 10:28
Y731-2	Kitchen Sink F.D.	1/30/2025	6:01	1	0.349	0.05	2/4/2025 10:28
Y731-3	Kitchen 3 Bay F.D.	1/30/2025	6:02	1	0.289	0.05	2/4/2025 10:29
Y731-4	1st Fl. Children Bath 1 F.D.	1/30/2025	6:04	1	0.292	0.05	2/4/2025 10:29
Y731-5	1st Fl. Children Bath 2 F.D.	1/30/2025	6:05	1	0.358	0.05	2/4/2025 10:30
Y731-6	1st Fl. Water cooler	1/30/2025	6:07	1	<0.05	0.05	2/4/2025 10:31
Y731-7	1st Fl. Womans Bath F.D.	1/30/2025	6:08	1	0.251	0.05	2/4/2025 10:33
Y731-8	1st Floor Mens Bath F.D.	1/30/2025	6:09	1	0.277	0.05	2/4/2025 10:35
Y731-9	2nd Fl. Child Bath 1 F.D.	1/30/2025	6:12	1	0.211	0.05	2/4/2025 10:36
Y731-10	2nd Fl. Child Bath 2 F.D.	1/30/2025	6:13	1	0.165	0.05	2/4/2025 10:36
Y731-11	Staff Bath 2nd Fl. F.D.	1/30/2025	6:15	1	0.1614	0.05	2/4/2025 10:37
Y731-12	Water cooler 2nd Floor	1/30/2025	6:16	1	<0.05	0.05	2/4/2025 10:37
Y731-13	Classroom 1	1/30/2025	6:18	1	0.241	0.05	2/4/2025 10:38
Y731-14	Classroom 2	1/30/2025	6:20	1	0.207	0.05	2/4/2025 10:38
Y731-15	Classroom 3	1/30/2025	6:22	1	0.358	0.05	2/4/2025 10:39
Y731-16	Classroom 4	1/30/2025	6:23	1	0.155	0.05	2/4/2025 10:39
Y731-17	Classroom 5	1/30/2025	6:26	1	0.18	0.05	2/4/2025 10:43
Y731-18	Classroom 6	1/30/2025	6:28	1	0.188	0.05	2/4/2025 10:43

Latish Menghani
Lab Director

CHAIN OF CUSTODY

VINELAND ENVIRONMENTAL LABORATORIES
Water and Wastewater Testing

782 S. Brewster Rd., Ste. B1, Vineland, NJ 08361
 (856) 692-6800 • Cell: (856) 297-3063 • Fax: (856) 692-3700

Page 1 of 1

Bill to Report to: (if different)

ent/Acct. No. CKS ST AL'S

Address Head Start

33 W Haddon Ave

City/State/Zip OAKLYN, NJ

Phone/Fax Joe Flood

Client Contact Joe Flood

P.O. No.

VEL Contact

Sampling Site Address: (if different)

LAB USE ONLY

PROJECT

FIELD ID

DATE

TIME

COLLECTION

DATE

TIME

LAB USE ONLY

DATE

TIME

LAB USE ONLY

DATE

TIME

LAB USE ONLY

DATE

TIME

LAB USE ONLY

DATE

TIME

LAB USE ONLY

DATE

TIME

LAB USE ONLY

DATE

TIME

LAB USE ONLY

DATE

TIME

LAB USE ONLY

DATE

TIME

LAB USE ONLY

DATE

TIME

Lab LIMS No: 1731

LAB USE ONLY:

Ascorbic/HCl Vials # HCl Vials

Na₂S₂O₃

Na OH/Zn acetate pH

HNO₃ pH Present in vial

H₂SO₄ pH

NaOH pH

Unpreserved

HCl pH

Temp control 20 ID #

MATRIX CODES

DW: DRINKING WATER

GW: GROUND WATER

WW: WASTEWATER

SO: SOIL

SL: SLUDGE

OIL: OIL

SOL: NON SOIL SOLID

MI: MISCELLANEOUS

X: OTHER

Field pH, Temp (C or F)

DO, Cl₂, S. Cond. etc.

214125

214125

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

ANALYSIS REQUESTED

Ascorbic - 6984 - 0.1614

50.05

0.2610

0.2070

0.3580

0.1550

0.1800

0.1880

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

1037

Field Parameters Analyzed By:

Date/Time:

Sig:

Report Format: Standard Forms

Standard + QC NJ Reduced Disk

Please call for pricing and availability on rush (<14-21 day) turnaround and on all but standard format.

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW. USE FULL LEGAL SIGNATURE, DATE AND MILITARY TIME (24 HOUR CLOCK). FE-8 AMHS 0800, 4 PM IS 1600

RELINQUISHED BY SAMPLER	DATE	TIME	RECEIVED BY	DATE	TIME	DELIVERY METHOD	VEL COURIER	CLIENT	Custody Seal Number
1 <u>Joe Flood</u>	<u>1/21/05</u>	<u>10:30</u>	<u>1</u>	<u>1/21/05</u>	<u>10:30</u>	<input type="checkbox"/> UPS <input type="checkbox"/> FEDEX <input type="checkbox"/> OTHER	<input type="checkbox"/>		
2			<u>2</u>						
RELINQUISHED BY			<u>3</u>						
RELINQUISHED BY			<u>4</u>						
RELINQUISHED BY			<u>5</u>						

Hazardous: Yes No